



NABL Recognized
Sub Divisional Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Vikasnagar.
Government Drinking Water Testing Laboratory
Ph (O): 9258186962, E-mail: jalkallab@gmail.com

Report ID: 117/UJS/SDLWQTML/2023-24

Dated: 12/02/2024

WATER QUALITY TEST REPORT

| | | | |
|--|--|--------------------|--|
| Name and Address of Organization/ Customer | Doon Valley Public School Bhagwanpur P.O Rajawala Dehradun | | |
| Product Description (Surface Water/ Ground Water/ Drinking Water) | Drinking Water | Sample Description | One Water Sample Collected From Doon Valley Public School |
| Reference Sample Identification: | SDLWQTML/UJS/2023-24-27 | | Date of Start of Analysis:09/02/2024 Date of End of Analysis:12/02/2024 |
| Date and Time of Sample Received:09/02/24 & 10:40AM | Sample Collected by: | | Customer |

| SN | Water Quality Parameters Under Chemical Scope | Results | Desirable Limit (BIS) | Permissible Limit (BIS) in the Absence of alternative source | Std. Test Method |
|-----|--|-----------|-----------------------------|--|----------------------------------|
| 1. | pH | 7.05 | 6.5 to 8.5 | No Relaxation | IS 3025 Pt-11, 2022 |
| 2. | Total Dissolved Solids (TDS), mg/L | 103 | 500 | 2000 | IS 3025 Pt-16-2023 |
| 3. | Turbidity, NTU | 0.02 | 1 | 5 | IS 3025 Pt-10-2023 |
| 4. | Total Alkalinity (as CaCO ₃), mg/L | 60 | 200 | 600 | IS 3025 Pt-23: 2023 |
| 5. | Total Hardness (as CaCO ₃), mg/L | 88 | 200 | 600 | IS 3025 Pt-21: 2009 Ra,2019 |
| 6. | Chloride, mg/l | 14.47 | 250 | 1000 | IS 3025 Pt-32: 2019 |
| 7. | Calcium (as Ca), mg/L | 21.6 | 75 | 200 | IS 3025 Pt-40: 2023 |
| 8. | Magnesium (as Mg), mg/L | 8.26 | 30 | 100 | APHA 23rd Ed.-3500-Mg B: 2023 |
| 9. | Colour, Hazen | 02 | 5 | 15 | IS 3025 Pt-04: 2021 |
| 10. | Odour | Agreeable | Agreeable | Agreeable | IS 3025 Pt-05: 2022 |
| 11. | Taste | Agreeable | Agreeable | Agreeable | IS 3025 Pt-08: 2012 |

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above

(Er.J.S.Chauhan)

Quality Manager
SDWQTM, LAB

Uttarakhand Jal Sansthan
Vikasnagar

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.



Sub Divisional Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Vikasnagar.
Ph (O): 9258186962, E-mail: jalkallab@gmail.com

Report ID: 117/UJS/SDLWQTML/2023-24

Dated: 12/02/2024

WATER QUALITY TEST REPORT

| | | | |
|--|--|--------------------|--|
| Name and Address of Organization/ Customer | Doon Valley Public School Bhagwanpur P.O Rajawala Dehradun | | |
| Product Description (Surface Water/ Ground Water/ Drinking Water) | Drinking Water | Sample Description | One Water Sample Collected From Doon Valley Public School |
| Reference Sample Identification: | SDLWQTML/UJS/2023-24-27-A | | Date of Start of Analysis:09/02/2024 |
| | | | Date of End of Analysis:12/02/2024 |
| Date and Time of Sample Received:09/02/24 & 10:40 AM | Sample Collected by: | Customer | |

| SN | Water Quality Parameters Under Chemical Scope | Results | Desirable Limit (BIS) | Permissible Limit (BIS) in the Absence of alternative source | Std. Test Method |
|----|--|---------|-----------------------------|--|-----------------------|
| 1. | Total Coliform,MPN/100ml | Absent | Absent | Absent | APHA 23 rd Ed.-9223-B |
| 2. | E.Coli,MPN/100ml | Absent | Absent | Absent | APHA 23 rd Ed.-9223-B |
| 3. | Residual Free Chlorine,mg/L | 0.0 | 0.2 | 1.0 | IS 3025Pt-26:1986 |

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

(Er.J.S.Chauhan)

Quality Manager
SDWQTM, LAB
Uttarakhand Jal Sansthan
Vikasnagar

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.